

Sec. 7 1/2-7. Lighting standards.

(a) Vehicular circulation and parking areas:

- (1) High pressure sodium fixtures shall be used with no direct glare onto adjacent properties or public streets.
- (2) Minimum light level within the parking area is 0.5 foot candles when the attendant facility is in use.
- (3) Standards, poles, and fixtures shall be a single color, uniform in design throughout the site and no taller than ten (10) feet above the building being served.
- (4) Creosote treated wooden poles are prohibited.

(b) Walkway lighting comprised of standard, pole, bollard and wall-mounted fixtures shall be no greater than twelve (12) feet above grade.

(c) Accent lighting:

- (1) Uplighting shall be concealed or positioned to screen the light source from adjacent property.
- (2) Floodlighting or spotlighting of architecture, graphics, or natural features shall not create spillage of light onto adjacent property or public streets.

(Ord. No. 835, § 1, Exh. A, 6-8-98)